



2025 ANNUAL WATER QUALITY REPORT

**RAMSEY WATER COMPANY
415 HIGHWAY 64 NW
P.O. BOX 245
RAMSEY, IN 47166
812-347-2551
IN5231005**

We are pleased to present Ramsey Water Company’s 2025 Annual Water Quality Report (Consumer Confidence Report) for January 1 – December 31, 2025. An electronic copy can be found at:

<https://ramseywater.com/water-quality-reports/>

This report provides details about where your water comes from, what it contains, and how it compares to the standards set by regulatory agencies. We routinely perform water quality test mandated by the EPA (Environmental Protection Agency) and IDEM (Indiana Department of Environmental Management). Our goal is to provide you with a safe and dependable supply of drinking water.

Contact Information:

If you have any questions about this report, please contact Ramsey Water at (812) 347-2551. If you want to learn more about your water utility, we invite you to attend our Annual Meeting on the second Monday in January at 7:30 pm at 415 Highway 64 NW at the Ramsey Water Office.

Where does your water come from?

Your drinking water comes from two sources. Ramsey Water Company’s groundwater wells are in Crawford County along the Ohio River. Additionally, we purchase water from Indiana-American Water Company, which has wells located in Clark County. A Wellhead Protection Plan for Ramsey’s well field that integrates geology and potential sources of contamination in the Wellhead Protection Area, is available at our office.

YOU TOO CAN HELP PROTECT GROUNDWATER

Recycle or properly dispose of household hazardous waste (HHW) and follow label instructions when applying herbicides or pesticides. Properly dispose of medicines, paint, batteries, etc.

How can you get involved?

Your involvement starts with the environment around you. Surface water and groundwater are continually being impacted by your actions. The most effective way to prevent groundwater contamination is through education about potential contamination sources and how to minimize or eliminate them completely.

Important information for the Spanish-speaking population: (Español)

Este informe contiene información muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuníquese con alguien que pueda traducir la información.

RAMSEY WATER COMPANY TEST RESULTS – IN5231005

Our water system tested a minimum of 15 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	Highest RAA	Range	MRDLG	MRDL	Units	Violation? Y / N	Typical Source
Chlorine	2025	1.0	0.44 – 2.06	4	4	ppm	N	Water Additive used to control microbes

Revised Total Coliform Rule-16 samples/mo.	Year	Highest Monthly No. of Positive Samples	MCLG	MCL	Likely Source of Contamination
Total Coliform	2025	0	0	MCL = <5% OR MCL = No more than 1 positive monthly sample	Naturally present in the environment.
E. Coli	2025	0	0	TT = No confirmed positive samples	Human and animal fecal waste

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical sampling of our drinking water may not be required on an annual basis; therefore, information provided refers back to the latest year of chemical sampling results.

Disinfection By-Products**	Collection Date(s)	Highest LRAA	Range	MCL	MCLG	Units	Violation? Y/N	Likely Source of Contamination
Total Haloacetic Acids (HAA5) Canal Ln	2025	23	25.2	60	0	ppb	N	By-product of drinking water disinfection.
HAA5 Despain Rd	2025	16	17.1	60	0	ppb	N	By-product of drinking water disinfection.
HAA5 Angel Run Rd	2025	17	14.7	60	0	ppb	N	By-product of drinking water disinfection.
HAA5 St Peters Church Rd	2025	21	18.1	60	0	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM) Canal Lane	2025	38	44.6	80	0	ppb	N	By-product of drinking water disinfection.
TTHM Despain Rd	2025	32	27.8	80	0	ppb	N	By-product of drinking water disinfection.
TTHM Angel Run Rd	2025	31	22.8	80	0	ppb	N	By-product of drinking water disinfection.
TTHM St Peters Ch Rd	2025	45	37.1	80	0	ppb	N	By-product of drinking water disinfection.

Lead and Copper*	Period	Range of Sampled Results	90 th Percentile	# Sites over AL	Action Level (AL)	Units	Violation? Y/N	Likely Source of Contamination
Copper, Free	2021 - 2023	0.014 – 0.657	0.428	0	1.3	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
Lead	2021 - 2023	0 – 1.12	0	0	15	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

*30 Sites were sampled for Lead and Copper

Inorganic Contaminants	Collection Date	Highest Level Detected	Range	MCL	MCLG	Units	Violation? Y/N	Likely Source of Contamination
Barium	6/6/23	0.093	0.093	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	6/6/23	0.711	0.711	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Radiological Contaminants	Collection Date	Highest Level Detected	Range	MCL	MCLG	Units	Violation? Y/N	Likely Source of Contamination
Gross Alpha excluding radon and uranium	12/5/23	<3.0	<3.0	15	0	pCi/L	N	Erosion of natural deposits.
Rad 226	12/5/23	<1.0	<1.0	AL 3	0	pCi/L	N	Erosion of natural deposits.
Rad 228 (Combined w/226)	12/5/23	<1.0	<1.0	Combined AL 5	0	pCi/L	N	Erosion of natural deposits.

Unregulated Contaminant Monitoring Rule 5:

- Ramsey Water PWSID#IN5231005 has sampled for a series of Unregulated Contaminants. Unregulated Contaminants are those that do not yet have a drinking water standard set by the EPA. The purpose of monitoring these contaminants is to help the EPA decide whether the contaminants should have a standard. We collected samples under the U.S. EPA UCMR*(Rule 5) for 29 PFAS compounds (and Lithium) in NOV 2025, MAR 2024, & SEP 2024 (and earlier under voluntary IN program). As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact Tim Nelson, Regulatory & Safety Supervisor at our office (812) 347-2551, by email: tnelson@ramseywater.com, or by mail, 415 Hwy 64 NW, Ramsey, IN 47166.

Unregulated Contaminant Monitoring Rule*	Collection Date	Highest Level	Range	MCL	MCLG	Units	Violation? Y/N	Likely Source of Contamination
Interim Perfluorooctanoic Acid PFOA (IDEM Voluntary Sampling)	6/12/23 1/23/24	4.8 7.8	4.8 – 4.8 7.8 – 7.8	-	-	ppt	N/A	Industrial chemicals in environment.
PFOA (UCMR SE1)	3/26/24	5.2	5.2 – 5.2	-	-	ppt	N/A	Industrial chemicals in environment.
PFOA (UCMR SE2)	9/11/24	4.0	4.0 – 4.0	4.0	0	ppt	N	Industrial chemicals in environment.
PFOA (UCMR SE3)	11/21/25	4.1	4.05 – 4.05	4.0	0	ppt	N	Industrial chemicals in environment.
Perfluorooctanesulfonic Acid PFOS (UCMR SE3)	11/21/25	2.47	2.47	4.0	0	ppt	N	Industrial chemicals in environment.
Perfluorobutanesulfonic Acid PFBS (UCMR SE3)	11/21/25	1.42	1.42	Hazard Index	Hazard Index	ppt	N	Industrial chemicals in environment.

For more information on the US EPA's PFAS drinking water standards, including the Hazard Index, please visit <https://www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas>

Why are potential contaminants in your drinking water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

Microbial Contaminants: such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants: such as salts and metals, can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides: may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants: including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants: can be naturally occurring or be the result of oil and gas production and/or mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Do you need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised individuals such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

*Additional required health effects information you should know about:

Lead Service Line Inventory:

- In 2024, the entire Ramsey Water distribution system was investigated for the presence of lead water mains and service lines, and none was found. An exhaustive review of existing paper records dating back to the 1960's, of more recent digital records kept on computer servers, and of returned customer surveys, approximately half of the 6100 customer services were eliminated as potentially containing lead. Nearly 2700 service lines were then excavated (vacuum or otherwise) to verify the remaining service line materials listed as unknown, were not lead.

- You can view this inventory for Ramsey Water online by clicking (County View) on Harrison County in the following IDEM Public Transparency Dashboard link: <https://idem.120water-ptd.com/#county> NOTE: The entire Ramsey Water System has been determined to be completely non-lead, if you wish to learn more about this initiative, please contact our office (812) 347-2551.
- There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant women, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

END of RAMSEY WATER COMPANY TEST RESULTS – IN5231005

INDIANA-AMERICAN WATER COMPANY TEST RESULTS – IN5210005

Regulated Contaminants:

Disinfection By-Products**	Year Sampled	Compliance Achieved	Highest LRAA	Range Detected	MCLG	MCL	Likely Source of Contamination
HAA5 (ppm)	2025	Yes	20.0	8.4 – 23.0	0	60	By-product of drinking water disinfection.
TTHM (ppm)	2025	Yes	72.8	27.6 – 72.8	0	80	By-product of drinking water disinfection.

Disinfectants	Collection Date	Compliance Achieved	Highest LRAA	Range Detected	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	2025	Yes	1.35	0.46 – 1.95	4	4	Water Additive used to control microbes.

Substance	Sampled		Compliance Achieved	MCLG	MCL	No. of Positive Samples	Likely Source of Contamination
E. Coli	SEP	2025	Yes	0	Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli.	0	Human and animal fecal waste
Total Coliform**	SEP	2025	Yes	0	Treatment Technique Trigger	1	Naturally present in the environment.

Although total coliform was detected, additional sampling showed that we were not in violation of the Treatment Technique (TT).

Inorganic Contaminants	Year Sampled	Compliance Achieved	Highest Compliance Result	MCLG	MCL	Range Detected	Likely Source of Contamination
Fluoride	2024	Yes	0.69	4	4	NA	Erosion of natural deposits; Water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate (N)	2025	Yes	0.25	10	10	NA	Runoff from fertilizer use; industrial or domestic wastewater discharge; Erosion of natural deposits.

Lead and Copper	Year Sampled	Compliance Achieved	MCLG	Action Level	90 th Percentile	# Sites over AL	Violation ? Y/N	Likely Source of Contamination
Lead	2024	Yes	0 ppb	15	ND	0	N	Corrosion of household plumbing systems.
Copper**	2024	Yes	1.3 ppm	1.3	0.026	0	N	Corrosion of household plumbing systems.

30 Sites were sampled for Lead and Copper.

Other Regulated Substances	Year Sampled	MCLG	SMCL	Level Found	Units	Range Detected	Typical Source
Chloride ¹	2024	NA	250	24.7	ppm	NA	Erosion of natural deposits; road salting.
Iron ¹	2025	NA	0.3	0.01	ppm	ND – 0.04	Naturally occurring.
Manganese ¹	2025	NA	0.05	0.02	ppm	0.001 – 0.034	Naturally occurring.
pH ¹	2025	NA	6.5 – 8.5	7.54	pH	7.39 – 7.70	Naturally occurring.
Sulfate ¹	2024	NA	250	43.0	ppm	NA	Erosion of natural deposits.

¹ – Substances with Secondary MCLs do not have MCLGs; these limits are primarily established to address aesthetic concerns.

INDIANA-AMERICAN WATER COMPANY TEST RESULTS – IN5210005 (Continued)

Other Substances of Interest	Year Sampled	EPA Guidance Level	Level Found	Units	Range Detected	Typical Source
Hardness	2025	NA	191	ppm	159 - 241	Naturally occurring.
Sodium**	2024	20	21.2	ppm	NA	Naturally occurring.

Unregulated Contaminant Monitoring Rule*

Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is necessary. Every five years, the EPA issues a new list of no more than 30 unregulated contaminants to be monitored. If you are interested in examining the results, please contact Indiana American Water at 1-800-492-8373. The Table below provides information on the unregulated contaminants that were detected in the water system under the current round of monitoring.

Unregulated Contaminant Monitoring Rule*	Compliance Achieved	Year Sampled	MCLG	MCL	Highest Level	Range	Typical Source
Perfluorooctanoic acid (PFOA) (ppt) ¹	Yes	2025	0	4	3.4	NA	Manufactured chemicals; used in a wide range of consumer products and industrial applications.
Perfluorooctanesulfonic acid (PFOS) (ppt) ¹	Yes	2025	0	4	3.3	NA	
Perfluorobutanesulfonic acid (PFBS) (ppt) ¹	Yes	2025	Hazard Index	Hazard Index	2.1	NA	

¹ – PFAS are currently regulated in Indiana at the levels listed. U.S. EPA has established national limits that we must meet by April 2029. For more information on the US EPA's PFAS drinking water standards, including the Hazard Index, please visit <https://www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas>

END of INDIANA AMERICAN WATER COMPANY TEST RESULTS – IN5210005

**Additional required health effects information:

- Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. NOTE: Verification samples tested negative for Coliforms and no violation for Treatment Technique occurred.
- Copper is an essential nutrient, but some people who drink water containing Copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing Copper in excess of the action level over many years can suffer liver or kidney damage.
- Some people who drink water containing Haloacetic acids (HAA5s) in excess of the MCL over many years may have an increased risk of getting cancer.
- For healthy individuals, sodium intake from water is relatively insignificant because a much greater intake of sodium comes from salt in the diet. However, sodium levels above the recommended upper limit may be of concern to individuals on a sodium-restricted diet.

Water Information Resources:

IDEM (Indiana Department of Environmental Management) – www.in.gov/idem
 CDC (Center for Disease Control) – www.cdc.gov
 EPA (Environmental Protection Agency) – www.epa.gov/safewater
 Safe Drinking Water Hotline – (800) 426-4791

Important Drinking Water Definitions

In the above tables, you will find many terms and abbreviations that you may not be familiar with. To help you better understand these terms, we've provided the following definitions:

- AL (Action Level):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- ALG (Action Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
- Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. Coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

AVG (Average): Regulatory compliance with some MCLs is based on running annual averages of monthly (or quarterly) samples.

LRAA (Locational Running Annual Average)

MCL (Maximum Contaminant Level): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MREM (Millirems Per Year): A measure of radiation absorbed by the body.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfection Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA (Not Applicable): Does not apply to this water system.

ND (Not detected): Laboratory analysis determined the constituent was not present at detection limits.

pCi/L (picocuries per liter): Measure of radioactivity in water.

PPM [Part Per Million or Milligram per liter (mg/l)]: One part per million equates to one ounce in 7,350 gallons of water.

PPB [Part Per Billion or microgram per liter (ug/l)]: One part per billion equates to one ounce in 7,350,000 gallons of water.

PPT [Part Per Trillion or Nanogram per liter (ng/l)]: One part per trillion equates to one ounce in 7,350,000,000 gallons of water.

RAA (Running Annual Average)

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

Variations and Exemptions = State or EPA permission not to meet an MCL or a treatment technique under certain conditions.